

STATE BANK OF INDIA
RBO MADHEPURA

PART-1

(Technical Bid)

TENDER FOR ELECTRICAL INSTALLATION WORKS AT NEW PREMISES OF AMY FORBESGANJ BRANCH

Name of the Tenderer : RBO MADHEPURA (63918)

Address : State Bank Of India, Regional business Office, Region- VI,
Near Railway Station, Madhepura-852113.

GSTIN : 10AAACS8577K2Z3

TENDER NOTICE

SBI RBO Madhepura invites tender in two bid system from interested SBI approved empanelled contractors having enlistment in **Electrical Installation Works [Category- 'AAA', 'AA', 'A', 'B', and 'C', (Work value above Rs.5.0 lakh and upto Rs.100.0 Lakh)]** under Patna Circle for undertaking **Electrical Installation Works at new premises of AMY Forbesganj Branch** through two bid tendering mode.

1.	Name of Work	:	Electrical Installation Works
2.	Tenders shall remain valid for	:	For a period of 90 days from the date of opening of price bid of tender.
3.	Earnest Money Deposit (EMD)	:	Rs.6260/ in the form of DD from any Nationalised Bank drawn in favour of State Bank Of India, RBO Madhepura. EMD of successful bidder will be converted towards Security deposit. The EMD of unsuccessful bidders will be refunded within 7 (seven) days of issue of work order to the successful bidder.
4.	Security Deposit	:	5% of value of work. The balance amount of Security Deposit excluding EMD will have to be submitted by the Vendor in the form of DD in favour of SBI RBO Madhepura within 7 (seven) days of acceptance of their offer. The Entire Security Deposit(including EMD) will be refunded after completion of defect liability period & satisfactory performance of work.
5.	Time allowed for completion	:	30 days from the date of issue of work order. The selected vendor will have to commence the work immediately on receipt of order.
6.	Estimated Cost	:	Rs.6.26 Lakh (approx)/- + GST
7.	Interim Payment	:	No interim payment will be made. Payment will be made after completion of work after submission of bill and necessary verification by Bank's Engineer.
8.	Availability of Tender Documents	:	Tender documents to be downloaded from the Bank's website www.sbi.co.in under ' Procurement News '
9.	Tender document downloading Start Date	:	From 02:00 P.M. on 06/10/2021
10.	Tender document downloading End Date	:	Upto 02:00 P.M. on 21/10/2021
11.	Last date and Time of submission of Tender	:	Upto 3.00 P.M. on 25/10/2021
12.	Date and Time of opening of Tender	:	25/10/2021 at 3.30 P.M.
13.	Defect Liability Period	:	6(Six) months from date of completion of work.
14.	Liquidated damages	:	0.5% per week of delay subject to maximum of 5% of contract value.

15.	Sealed tenders should be submitted within the specified date & time to the office of Regional Manager, State Bank of India, Regional Business Office, Near Railway Station Madhepura-852113.
16.	
(a)	
(b)	<p>Sealed tenders are invited from the Bank's Empanelled Contractors as mentioned in NIT in two parts, i.e. Cover-I and Cover-II separately. Sealed tenders in two parts i.e. cover-I and Cover-II are to be submitted.</p> <p>(a) Cover-I (Technical Bid): Technical bid envelope shall contain the following documents: (i) Details of EMD. (ii) Technical Bid duly signed & stamped in each page. Cover-I will be opened as per above mentioned date & time in the presence of Tenderers who desire to attend.</p> <p>(b) Cover-II (Price Bid): Shall contain the price offered by the vendor. No condition/stipulation in Cover-II other than unconditional general rebate shall be accepted. Cover-II (Price Bid) will be opened only of those bidders who are successful in Technical Bid(Cover-I) after thorough scrutiny.</p>
(c)	The Bidder is expected to examine all instructions, forms, terms and specifications in the bid documents. Failure to furnish all information required as per the Bid Documents or submission of bids not substantially responsive to the Bid documents in every respect will be at the bidders risk and shall result in rejection of the bid.
(d)	In case the date of opening of tenders is declared as a holiday, the tenders will be opened on the next working day at the same time.



Regional Manager



ANNEXURE-III

PRICE BID

Price Bid for Electrical Installation Works at new premises of AMY Forbesganj Branch

Sl.No.	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	Amount (Rs.) (Exclusive of GST on work contract)
1	MAIN INCOMING SOURCE PANEL (MISP) : Supply, installation, testing and commissioning of main incoming (MIP) Panel suitable for wall /floor mounted indoor type, air insulated, totally enclosed vermin-proof , dead front, cubicle type, 2 mm thick sheet steel enclosure use on 415 V, 3 Ph., 4 wire, 50 Hz. A.C. system, instrumental panel, CTs, incoming and outgoing cable compartment. The Panel shall be complete in all respect as per site requirement, interconnection, G.I. earth busbar of adequate size covering the total length of switch board with drilled holes, G.I. bolts, nuts, washers etc. as directed by E-I-C. The cubicle should be painted with two coats of light grey synthetic enamel paint over two coats of zinc chromate primer. The complete fabrication, construction shall be done as per the site condition and conforming to the relevant IS. Approval of Manufacturer's drawings from E-I-C.				
	The Panel consists of the following INCOMING : 1 No. : 415V, 200A 4P MCCB (35/36 KA), for Main Line , 1 No. : 415V, 125 A 4P MCCB (35/36 KA), for DG Incoming , 1 No. : 415V, 125 A 4P On-Load Changeover Switch 2 No. : Digital Multi Function Meter (MFM) one for DG and one for main Line 6 Nos.: LED Phase indicating lamps. 6 Nos.: Suitable CTS(200/5) PVC sleeved TPN Tinned 200 Amps Copper Busbar with suitable Double Bus bar System (such that DG Set should feed power to UPS VTPN and ATM VTPN in case of power failure through on load change over switch) G.I. EARTH BUSBAR 25mm x 3mm covering the total length of panel. OUTGOING : Termination I: (To be connected with Change over) 1 No: 125A 4P MCCB (35/36 KA) for UPS ,Raw & Lighting VTPN 1 No: 63 A 4P MCCB (35/36 KA) for ATM Supply VTPN Termination-II: (Not to be connected with Change over) 1 No: 100 A 4P MCCB (35/36 KA) for AC VTPN	SET	1		
2	Sub-main line:- Wiring in MS conduit of IS specification of Proper size with core PVC insulated stranded copper wire 1.1KV grade (Finolex/Havells/Polycab/RR Kabel/ Richa/KEI or equivalent) and with supply ,installation, commissioning of all the materials required including proper termination, connection in complete as required from main DB to various DBs of approved Make:-				
i)	With 2 nos. 6 Sq.mm + 1 no. 6 Sq.mm. (green colour for earth) PVC insulated copper wire in MS conduit for LDB/PPDB/CDB or as per site requirement.	RM	120		
ii)	With 2 nos. 6 Sq.mm + 1 no. 6 Sq.mm. (green colour for earth) PVC insulated copper wire in MS conduit for 5 KVA UPS or as per site requirement.	RM	40		
iii)	With 2 nos. 4 Sq.mm + 1 no. 4 Sq.mm. (green colour for earth) PVC insulated copper wire in MS conduit for AC Wiring or as per site requirement.	RM	150		

Sl.No.	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	Amount (Rs.) (Exclusive of GST on work contract)
3	Supply ,installation ,testing and commissioning of distribution board manufactures made sheet steel enclosure With the following MCBs (DB, MCB and MCCB approved make) and connecting the same to the system.Make - Legrands/ Havells/L&T/SIEMENS/Hager or equivalent)				
i)	Computer DB, SPN double door with 40A (30mA-100 mA sensitivity) DP RCCB as incomer & 8 nos 10A SP MCB as outgoing.	No.s	2		
ii)	Raw Power DB, SPN double door with 40A (30mA-100 mA sensitivity)DP RCCB as incomer & 8 nos 10A SP MCB as outgoing.	No.s	2		
iii)	DB with 63 A DP MCB.	No.s	2		
iv)	A) UPS OUTGOING DB for UPS : Supply of all required materials and fixing of output UPS box (Company made) having provision of the following arrangement complete with all respects as per the direction of engineer in charge. Incoming: 1 no. 63 A DP MCB Outgoing: 5 No. 40A (10KA) DP MCB		1		
v)	DB with 25 A DP RCCB (30mA to 100 mA), AC Socket & Top for AC complete in all respect	No.s	7		
vi)	VTPN Double Door Distribution Board with provision of fixing MCCB as incomer,having vertical fish bone busbar, with all internals such as DIN channels,neutral link,internal wiring ,termination of circuits complete in all respects with housing of following:-125A 4 Pole MCCB (36kA) as incomer and 06 Nos. 40 A SP MCB's, 04 Nos 32 A SP MCB's and 02 Nos 63 A SP MCB at outgoing . approved make	Set	1		
vii)	VTPN Double Door Distribution Board with provision of fixing MCCB as incomer,having vertical fish bone busbar, with all internals such as DIN channels,neutral link,internal wiring ,termination of circuits complete in all respects with housing of following:-100 A 4 Pole MCCB (36kA) as incomer and 12 Nos. 32 A SP MCB's at outgoing .	Set	1		
viii)	LDB : Consumer unit SPN MCB DB complete with all respects and the following MCBs. INCOMING : 1 No. 240V 32A(10KA) (30mA-100mA) DP MCB OUTGOING : 8 Nos. 240V 6A-16A (10 KA) SP MCB.	Set	1		
4	Supplying, installation, testing & commissioning,laying,lugging,etc of PVC insulated aluminium armoured 1.1 KV grade 3.5 cored cable of following size with making proper trench/support on wall as per IS specification and complete with all respect as per the instruction of Engineer-In-Charge(E-I-C) .				
i)	With 3.5 core x 35 sq. mm cable	RM	90		
ii)	With 3.5 core x 95 sq. mm cable	RM	60		
5	Copper bonded Rod Earthing. SITC of OBO Betterman/JK/JEF eco safe/ make earthing system - * - UL Listed Earth Electrode - Copper bonded low carbon steel electrode, coating 250 microns - Tested as per IEC 62561-2 - Meets the requirement of IS 3043 and In one set it should include: a) One nos of Earthing rod-Type 17 3000 CCER, Length - 3000 mm Outer Dia - 17.2 mm Copper bonded low carbon steel Electrode WITH 250 microns copper bonded b) One bag (10 KG) Earth Enhancement Compound confirming to IEC 62561-7 c) One nos of universal clamp . Product Certificate of company must be provided. Earth Test Report to be submitted.	No.s	2		
6	SITC of Earth distribution Box (Bus Bar Station) to be installed in the branch near Main Panel and UPS, comprising of a bus bar of 3x25x180mm Cu strip .	SET	2		

Sl.No.	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	Amount (Rs.) (Exclusive of GST on work contract)
7	Supply and laying of 8 SWG Cu cotton coated wire in 20mm dia rigid PVC conduit for earthing From the earth pit to the Main panel/UPS.	Mtr.	120		
8	Computer Socket Outlet: Computer point wiring in MS conduit of IS specification of proper size with 2 Nos. 2.5 Sq.mm. + 1 x 2.5 Sq.mm. (green colour for earth) PVC insulated copper wire (1.1 KV grade FRLS/FR-LSH) in pre - laid (as per ISI) single core PVC insulated stranded copper wire 1.1KV grade(Finolex/Havells/Polycab/ RR Kabel/ Richa/KEI or equivalent) and with all material supply installation and commissioning complete from CDB/PDB(Raw) .The wiring shall be carried out on surface above false ceiling by chiseling the existing surface and plastering the same with cement etc. after fixing the MS conduit with all accessories like saddles screws, bends T-joint etc. 2 coats of painting Matching to the surface including supply installing, testing, commissioning of modular plate type switch and socket:Each computer socket outlet cluster consists of following 4 nos 6/10A 5 pin modular type International sockets with single 16A Modular type controlling switch with indicator on table top. (Legrands / MK or equivalent) for computer terminal on sheet steel enclosure (cadmium plated),duly fitted with screw to the steel conduit and fixed to the wall partition furniture with all interconnection and proper earthing .All the opening shall be covered with blank plate and be sealed to make the box vermin proof.B48	No.s	10		
9	Raw Power point wiring in MS conduit of IS specification of proper size with 2 Nos. 2.5 Sq.mm. + 1 x 2.5 Sq.mm. (green colour for earth) PVC insulated copper wire (1.1 KV grade FRLS/FR-LSH) in pre - laid (as per ISI) single core PVC insulated stranded copper wire 1.1KV grade(Finolex/Havells/Polycab/ RR Kabel/ Richa/KEI or equivalent) and with all material supply installation and commissioning complete from RPDB/PDB(Raw) .The wiring shall be carried out on surface above false ceiling by chiseling the existing surface and plastering the same with cement etc. after fixing the MS conduit with all accessories like saddles screws, bends T-joint etc. 2 coats of painting Matching to the surface including supply installing, testing, commissioning of modular plate type switch and socket:Each computer socket outlet cluster consists of following : 2 nos 16/20A 5 pin modular type International sockets with single 16/20A Modular type controlling switch. (Legrands / MK or equivalent) for computer terminal on sheet steel enclosure (cadmium plated),duly fitted with screw to the steel conduit and fixed to the wall partition furniture with all interconnection and proper earthing .All the opening shall be covered with blank plate and be sealed to make the box vermin proof.B48	No.s	10		

Sl.No.	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST on work contract)	(Exclusive of GST on work contract)
10	POWER SOCKET OUTLET AND ITS WIRING Raw power socket outlet cluster point including supply and fixing of modular type socket outlet clusters components AND WIRING 1100V grade, FRLS complete in all respect as detailed below. 1 Nos. 16/20A 5 pin modular type international sockets and 1 No. 16/20A modular type controlling switch with 2 Nos. 4 Sq.mm. + 1 x 2.5 Sq.mm. (green colour for earth) PVC insulated copper wire in pre-laid (as per ISI) M.S. conduit including interconnection, painting etc. as required to be completed in all respect from DB to UPS/RAW Power Outlet. Proper colour code must be followed.	No.	4		
11	Wiring for light/fan/exhaust fan points using 3 X 1.5 Sq MM 1.1 KV grade PVC insulated stranded copper conductor wire (Finolux/Havells/Richa/RR Kabel/KEL/Polycab or equivalent) for phase, neutral and earth in 25 mm dia heavy duty MS conduit along with associated accessories like MS junction boxes, bends, saddles, screws etc. concealed in wall, floor, under flooring, below false ceiling or on surface as well as suspended from ceiling with 25mm X 3 mm MS flat suspenders duly painted above false ceiling from individual light/fan/exhaust Fan point outlet, etc. to individual modular type switch boards, 10 Amp modular plate type switches etc. (MK/Legrand/Havells or equivalent), as required complete including circuit wiring with 3 X 2.5 sqmm. 1.1 KV grade PVC insulated stranded copper conductor wire and as per site requirement and as instructed by Engineer-in-Charge.	No.s	62		
!!	One light controlled by one switch	No.s	12		
!!!	Glou sign board wiring	No.	1		
!v)	6/10 A modular socket & switch at same board	No.s	5		
v)	Ceiling Fan Point with electronic modular type regulator (2 module step, 120 watt rating)	No.s	2		
vi)	UPS light points	No.	4		
vii)	Exhaust fan point	No.	6		
Part B - SUPPLY AND INSTALLATION OF ELECTRICAL FITTINGS					
12	Supply, installation, testing & Commissioning of 36W-2'X2' LED Panel light/luminaire recessed mounted complete with all accessories. lumens >3000. Make: Philips/Wipro/Crompton Greaves/HPL/Halonix/Syska	No.s	8		
13	Supply, installation, testing & Commissioning of 15W LED Downlighter recessed mounted of make complete with all accessories Make: Philips/Wipro/Crompton Greaves/HPL/Syska/Halonix/Havells	No.s	36		
14	Supply installation testing and commissioning of 18W LED Batten with glare free light fitting complete with all respect. Make :- Batgl/Havells/Philips/Wipro/Crompton/Syska or equivalent	15 Nos	14		
15	Supply & fixing of 35W LED Street Light with suitable mounting pipe & CFL Lamp etc. of Syska / Philips / Wipro / CG / HPL / Halonix/Havells complete in all respect	No.	2		
15	Supply and installation of Wall Mounted fan 400/450 mm, 3 pin Metallic Blade, 1400 rpm of crompton/bajaj/usha/orient/Havells/ Polar make or equivalent	No.s	12		

SI.No.	Description	UOM	Qty.	Rate (Rs) (Exclusive of GST on work contract)	Grand Total (in Rs)
16	Supply and installation of Ceiling fan 1200 mm	No.s	2		
17	Supply and installation of Exhaust Fan complete with all respect. Make: crompton/bajaj/usha/havells/orient make	No.s	6		
Part C - LAN CABLING WORK					
18	Supply and laying of E-Cat 6 UTP cable for the Data Circuit through the PVC conduit. Rate to include for termination on both end or as directed by E-I-C(Make: D-Link, AMP, HCL,DIGISOL)	Mtr	450		
19	Supply and fixing of information outlet box suitable for 1 nos, RJ 45 terminals including mounting box(PVC) & top cover, to be fixed a concealed manner in partition by necessary bolts & nuts or as directed at site.(Make: D-Link, AMP, Legrand ,HCL,DIGISOL)	No.s	10		
20	Supply of 2 mtr. Long E-CAT 6 PATCH CHORD (Make: D-Link, AMP, HCL, Legrand, Digisol)	No.s	10		
21	Supply & installation of 9U Rack with power supply arrangement, ventilation fan, mounting racks etc. Complete with all accessories.	No.	1		
GST on work contract will be extra as applicable.					