

**TENDER ID: MUM20240126**

**PROPOSED CIVIL CONSTRUCTION OF SPECIAL CURRENCY ADMINISTRATION BRANCH AT BANK OWN PREMISES ON PLOT NO. 2, MIDC, DOMBIVILI (E), DIST: THANE,  
FOR STATE BANK OF INDIA**

**Pre-bid Queries**

**Meeting Date: 03.02.2024**

S. No.	Bidding Document		Subject	Contractor's Query	SBI's Reply
	Page No.	Clause No.			
1	6	4.0 of ITT	EMD	EMD is required for MSME or not?	The MSMEs have been exempted to submit EMD subject to submission of relevant valid certificate for this work for claiming exemption.
2	166	Item 5 of Price Bid	RCC Work	Is M-40 will be site-batch?	Only M-25 grade concrete is site batch & other will be RMC. All the RCC mix should be pre-approved.
3	166	Item 5 of Price Bid	RCC Work	Where will site-batch used?	It will be used in small items, like chajja, staircase etc. It will be used as per the direction of Architect/ Engineer-in-charge.
4	167	Item 5.c of Price Bid	RCC Work	RMC make?	RMC should only be used from approved brand from their own plant. All the relevant documents should be submitted to Architect/Engineer-in-charge.
5	167	Item 6 of Price Bid	TMT Bars	Steel make?	Reinforced steel must be from approved make as mentioned in tender.
6	169-170	Item 8, 9 & 10 of Price Bid	Plaster work	Plaster work?	All the plaster work will be including dash coat & two or more coats.
7			General Query	Which staircase need to be demolish?	As mentioned in tender drawings.