

Fire Fighting Work at Ground Floor Control Room of LHO Lucknow Building					
Sr No.	DESCRIPTION OF ITEMS	QUANTITY	UNIT	RATE (Rs.)	AMOUNT (Rs.)
1	<b>M. S. Pipe</b>				
	Providing, fixing, testing and commissioning of Above Ground <b>M.S. ERW Black C Class Heavyduty pipes as per IS: 1239</b> including cutting, screwing, welding etc. and providing all fittings like flanges, bends, tees, elbows, reducers, clamps, hangers etc. with painting of one coat of primer and 2 or more coats of synthetic enamel paint of approved make / shade complete as per specification (MAKE TATA/ JINDAL)				
a	25mm dia	70	RMT		
b	50mm dia	48	RMT		
c	65mm dia	30	RMT		
d	80mm dia	42	RMT		
e	100mm dia	6	RMT		
2	Providing, Fixing, Testing and Commissioning of <b>C.I.Butterfly valve</b> conforming to I.S:13095 class PN 1.6 rating with Fittings, Flanges, Nutbolts, Washers, Gaskets etc.of size: Make Keystone/Audco				
a	80mm dia	2	Nos		
3	Supply, installation,Testing & Commissioning (SITC) of <b>pressure guage</b> 0-200 PSI range, 3/8" BSP bottom entry 4" dial weather proof with stainless steel internals, siphon tube and gate valve/ Isolation cock including fittings, etc. complete as required with Ball Valve.	2	Nos		
4	Sprinkler Head (HD/Tyco /Viking any Standard Brand/Approved Brand) with complete fitting (below false ceiling)	30	Nos		
5	Metallic Flexible pipe for sprinklers head (As per number of Sprinklers in down)	30	Nos		
6	Supply and installation of flow switch 80 MM dia Make System Sensor/Potter	2	Nos		
7	Ball Valve 25 MM	2	Nos		
8	SITC of 2 core wire for connection of flow switch to annunciator panel. (polycab/finolex/anchor)	75	RMT		
	<b>TOTAL AMOUNT (Rs.)</b>				