



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2023/B/3698388
Dated/दिनांक : 15-07-2023

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	31-07-2023 16:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	31-07-2023 16:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Finance
Department Name/विभाग का नाम	Department Of Financial Services
Organisation Name/संगठन का नाम	State Bank Of India (sbi)
Office Name/कार्यालय का नाम	Lho Lucknow
Total Quantity/कुल मात्रा	1
Item Category/मद केटेगरी	Solar Power Plant (Roof Top) for ONGRID System, Three Phase (Q3)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	15 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	2 Year (s)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance/विगत प्रदर्शन	80 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid

Bid Details/बिड विवरण	
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Estimated Bid Value/अनुमानित बिड मूल्य	5000000
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	50000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	60

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

ASST GENERAL MANAGER

State Bank of India, 1st Floor, B wing, Local Head Office, Motimahal Marg, Hazratganj, Lucknow-226001 contact no 0522-2295361/365

(Agm Premises And Estate Lho Lucknow)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

Reserved for MSE

Reserved for MSE	Yes
------------------	-----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
3. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.
4. Procurement under this bid is reserved for purchase from Micro and Small Enterprises whose credentials are validated online through Udyog Aadhaar for that product category. If the bidder wants to avail the reservation benefit, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service.
5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.
6. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Unbranded LED Solar Power Plant (Roof Top) For ONGRID System, Three Phase 100 Kw Power With Voltage 200 V To 800 V (1 set)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/कमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
INVERTER	Rated out put power of inverter (Kw)	100
	Switching device	IGBT
	No. of Phase (in Nos.)	3
	Inverter output wave form	Pure sine wave
	No. of MPPT per inverter (in Nos.)	1, 2, 4
	No. of string at input side of inverter (input port +ve and -ve) (hint: 1 sets contains 1 +ve and 1 -ve port)	1 set, 2 sets, 3 Sets, 4 Set
	Maximum power point tracker	Integrated in the PCU/inverter to maximize energy drawn from the array
	Operating Voltage Range of Inverter	200 V to 800 V
	Over load support at Input side, DC	20% of Maximum Input Voltage for 3 phase system, 30% of Maximum Input Voltage for 3 phase system, 10% overload DC Capacity, 15% of Maximum Input Voltage
	Maximum input current for each MPPT (in A)	28.5
	Service condition	Outdoor
	Ingress protection rating of inverter	IP 65 (for outdoor use)
	Cooling medium for inverter	Intelligent fan cooling
	Manual switch for disconnecting DC supply	Yes
Inverter mounting type	Wall Mounted	
GENERIC	A Grid Tied Photo Voltaic (SPV) power plant consists of	SPV array, Module Mounting Structure, Power Conditioning Unit (PCU) consisting of Maximum Power Point Tracker (MPPT), Inverter, and Controls and Protections, interconnect cables and switches
	PV Array Mounting	Mounted on a suitable structure
	Grid tied SPV system is	Without battery and designed with necessary features to supplement the grid power during day time.
	Installation and testing for complete system	Yes including Civil Work, Designing, Fabrication, Cabling Work with suitable Bolts, Nuts, Clamps, Connectors and testing etc
INVERTER OUT PUT	Maximum current for 3 phase inverter (in A)	19.1, 23.8, 27, 31.8, 41.7, 50, 83.3, 100

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Output voltage (in V)	415 for 3 phase, 240 V Single Phase
	Invert auto trip at output side	Lower : at 304 V, Higher : at 460 V with adjustable, Lower : at 313 V, Higher : at 470 V wit adjustable, Lower : at 160 V, Higher : at 285 V with adjustable
	Overall Efficiency (in %)	>90
PROTECTION FOR INVERTER	Overload protection	110% for 1 Minute, 125% for 30 sec, 150% for 5 sec
	Over temperature protection	Yes at 65 Deg. C Cooling Fan will auto switch ON, Yes at 65 Deg. C shutdown
	Surge protection	Metal Oxide Varistor (MOV)
	Insulation Resistance Monitoring	Yes, No
	Grid Monitoring protection	Yes, No
	Power factor at rated out put power	> 0.9, 0.9
SERVICE CONDITION	Operating temperature	-25 to +60 deg. C, -20 to +50 deg. C
DISPLAY FEATURES ON INVERTER	Type of display	LED
	Display parameters	DC Voltage, DC Current, AC Voltage, AC Current, Out put frequency, Power Factor
	Generating power Data storage facility	Yes for 2 Years from the date of commissioning
	Interface facility for transmitting the generating power data for cloud storage	Inbuilt Wifi Enabled, With Wifi Dongle, With GPRS Dongle without SIM card, With RS 485
	Net meter	Approved by Government of India/State Government authority concerned for connecting to Grid
Add on items - DC DISTRIBUTION BOARD	DC Distribution panel to receive the DC output from the array field	Yes with surge arrestors
	Ingress protection (Enclosure protection) of DC Distribution Box	IP65
	Material of bus bar and size	Copper, size as per inverter rating
	Circuit Breaker for input side (DC side) for each inverter	MCB 10 A, MCB 15 A
Add on items - CABLE FOR INPUT	ISI Marked Connecting cables according to Inverter rating for each system	PV Module to Inverter DC
	Electric Cable for Input	1C x 4 Sq. mm, Copper Cable (as per IS:694:2010 latest), 1C x 6 Sq. mm, Copper Cable (as per IS:694:2010 latest)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Cable Length for PV Module to Inverter, DC (in m)	5, 10, 15, 20, 25
Add on items - AC DISTRIBUTION BOARD	AC Distribution Panel Board (DPB) for controlling the AC power from PCU/inverter	3 Phase 415 Volt +/- 10%, 50 HZ +/-3 Hz
	Panel construction	Metal clad, totally enclosed, floor mounted, air insulated, cubical type with change over switch
	Ingress protection (Enclosure protection) of AC Distribution Box	IP54 for Indoor, IP65 for outdoor
	All switches and the circuit breakers, connectors should conform to	IS:60947 part I, II and III.
	Panels designed for minimum expected ambient temperature	45 deg. C
	Circuit Breaker for output side (AC side) for each inverter	MCB 10 A, MCB 16 A, MCB 20 A, MCB 25 A, MCB 32 A, MCB 40 A, MCB 63 A, MCB 100 A
Add on items - CABLE FOR OUTPUT	ISI marked Connecting cables according to Inverter rating for each system	From Inverter to Net Meter and to mains at LT Bus bar while in grid tied mode
	Conformity of the specification for cable	3.5C x 6 Sq. mm, Copper Cable (as per IS:694:2010 latest), 3.5C x 10 Sq. mm, Copper Cable (as per IS:694:2010 latest), 3.5C x 16 Sq. mm, Copper Cable (as per IS:694:2010 latest), 3.5C x 35 Sq. mm, Copper Cable (as per IS:694:2010 latest), C X 6 Sq. mm, copper cable (as per IS:694:2010 latest, C X 10 Sq. mm, copper cable (as per IS:694:2010 latest, 2 C X 16 Sq. mm, copper cable (as per IS:694:2010 latest, 2.5 sq. mm 2 core copper cable, 4 sq. mm 2 core copper, 4 sq. mm 4 core copper, 10 sq. mm 4 core Aluminium, 16 sq. mm 4 core Aluminium, 25 sq. mm 3.5 core Aluminium, 35 sq. mm 3.5 core Aluminium, 50 sq. mm 3.5 core Aluminium, 70 sq. mm 3.5 core Aluminium, 95 sq. mm 3.5 core Aluminium
	Cable length for output side (from inverter to Net Meter for each system) (in m)	5, 10, 15, 20, 25, 30, 35, 40
Other Add on Items	Cabling work at input side for each system	With PVC Conduit pipe with necessary clamps and screws, With G.I. Cable Tray with fitment accessories
	Cabling work at Output side for each system	With G.I. Cable Tray with fitment accessories
	Danger boards and signages	1 No
ARRAY STRUCTURE	Material of mounting structure for mounting the modules/ panels/arrays	Structural Steel, Grade: E300 (as per IS:2062:2011 latest)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
JUNCTION BOX	Material of Junction Box	GRP(Glass reinforced plastic), FRP (Fibre reinforced plastics), Powder Coated Aluminium, cast aluminium alloy
	Ingress protection (Degree of Protection) for Junction Box	IP65, IP67, IP68
Wind Load	The Mounting structure shall be so designed to withstand the speed for the wind zone of the location where a PV system is proposed to be installed	Yes
	Compliance to wind velocity test for the Mounting structure of PV System	as per IS 875:1987 part 3 latest
	Regional wind withstand capacity which the Mounting structure of PV system support is suitable to withstand (in Km/Hour)	180
WARRANTY & GUARANTEE	Minimum guarantee for maintaing of out put peak watt capacity	> / = 90% at the end of 10 years and >/= 80% at the end of 25 years
CERTIFICATIONS	Availability of type test reports for PCU/Inverter, PV Module to prove the conformity of the specifiction from	Central Govt.LAB, MNRE approved Lab, NABL Acreedited LAB, BIS approved Lab, ILAC Accredite d lab

Additional Specification Parameters - Solar Power Plant (Roof Top) For ONGRID System, Three Phase (1 set)

Specification Parameter Name	Bid Requirement (Allowed Values)
Solar plate module	Mono C-Si PERC 530 watt above
Remote monitoring	net meter & SIM based remote monitor feature with one year recharge by vendor
Solar plate cleaning arrangement	Solar plate Cleaning arrangement at rooftop with CPVC water pipe
LED display system with Graph	Graph of hourly solar power generation, E-day, E-total (Kwh) solar power generation details on inverter LED display simultaneously must be available
Solar plate module	Mono C-Si PERC 530 watt above

Specification Parameter Name	Bid Requirement (Allowed Values)
Remote monitoring	net meter & SIM based remote monitor feature with one year recharge by vendor
Solar plate cleaning arrangement	Solar plate Cleaning arrangement at rooftop with CPVC water pipe
LED display system with Graph	Graph of hourly solar power generation, E-day, E-total (Kwh) solar power generation details on inverter LED display simultaneously must be available

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Pramod Kumar	226001, State Bank of India, Local Head Office, Moti Mahal Marg, Hazratganj	1	45

Buyer added Bid Specific Additional Scope of Work

S.No./क्र.सं.	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items
1	NIT View	SUPPLY AND INSTALLATION OF 100 KWp SOLAR POWER PLANT AT PARKING AND SUSTATION OF LOCAL HEAD OFFICE, LUCKNOW	Solar Power Plant (Roof Top) For ONGRID System, Three Phase(1)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. Service & Support

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

3. **Generic**

After award of contract – Successful Bidder shall have to get Detailed Design Drawings approved from buyer before starting fabrication. Successful Bidder shall submit Detailed Design Drawings for Buyer's approval, within 7 days of award of contract. Buyer shall, either approve the drawings or will provide complete list of modification required in the drawings within 5 days. Seller shall be required to ensure supply as per approved Drawings with modifications as communicated by Buyer. If there is delay from buyer side in approval of drawing– the delivery period shall be refixed without LD for the period of delay in approval of Drawing.

4. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

AGM (Premises & Esatate) LHO Lucknow
payable at
Lucknow

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

5. **Forms of EMD and PBG**

Bidders can also submit the EMD with Banker's Cheque in favour of

AGM(Premises & Estate) LHO Lucknow
payable at
Lucknow

Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

6. **Warranty**

Bidder / OEM has to give an undertaking that after expiry of warranty period, it will provide AMC Service for next 5 years for the offered products at the rate not more than 10 % of contract price per annum. Buyer reserves the right to enter into an AMC agreement (covering preventive maintenance and servicing)with the Successful Bidder / OEM after expiry of the Warranty period at rate as mentioned above and the payment for the AMC charges would be made Quarterly after rendering of the AMC Services of the relevant AMC period. Performance Security of the successful bidder shall be forfeited if it fails to accept the AMC contract when called upon by the buyer. The original Performance Security of contract will be returned only after submission and verification of AMC Performance Security for 2% of total AMC value valid up to AMC period plus 2 months (if there is no other claim). (Undertaking of acceptance to be uploaded with bid).

7. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

8. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

9. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

Vendors who have already awarded three or more ongrid solar works by our dept and these works are not completed as on 15.07.2023 and completion period as per contract has been expired, Such firms are not eligible for participating in this bid. If such

firms participated in this bid, these firm will be rejected in technical bid and their price bid will not be opened.

10. **Warranty**

Warranty period of the supplied products shall be 5 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

11. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

12. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

13. **Service & Support**

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

14. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

15. **Warranty**

Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 3 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

16. **Past Project Experience**

The Bidder / OEM {themselves or through reseller(s)}, should have executed project for supply and installation / commissioning of same or similar Category Products during preceding 3 financial years (i.e. current year and three previous financial years) as on opening of bid, as per following criteria:

- (i) Single order of at least 35% of estimated bid value; or
- (ii) Two orders of at least 20% each of estimated bid value; or
- (iii) Three orders of at least 15% each of estimated bid value.

Satisfactory Performance certificate issued by respective Buyer Organization for the above Orders should be uploaded with bid. In case of bunch bids, the Category related to primary product having highest bid value should meet this criterion

17. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

18. **Generic**

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---